

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7125-1130:157 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: *Honeywell International Inc., 1500 W. Dundee, Arlington Heights, IL 60004-1472
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

DESIGN: Models SC813B 2001, SC813B 1005, SC813B 1003 and 14507326-002 strobe lights (minimum 15 cd). Ceiling and wall mount.

Models SC813B 2027, SC813A 1021, SC813B 1037 and 14507326-005 strobe lights (minimum 15/75 cd). Wall mount only.

Models SC813B 2019, SC813A 1013, SC813B 1011 and 14507326-004 strobe lights (minimum 75 cd). Ceiling and wall mount.

Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as strobe lights for the hearing impaired when used in conjunction with separately listed compatible fire alarm control units. For indoor use only.

XLF: 7125-0785:116

*Rev. 06-14-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**